

Data summary tables for Dee Valley Water (DVW)

These tables contain a summary of results of monitoring undertaken by the water company in 2017 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2017*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.defra.gov.uk>

Notes relating to the interpretation of the tables:

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 11 July 2018
Drinking Water Inspectorate
Area 1A
Nobel House
17 Smith Square
London
SW1P 3JR

Enquiries: 0300 068 6400

Site Summary Data for Dee Valley Water Plc

Report Date Range: For the whole year 2017

Table DVW 1: Quality of water leaving treatment works - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Total)	A013B	0.1 mg NO ₂ /l	50	0	0	< 0.007	0
Totals:			50	0			

Table DVW 2: Quality of water leaving treatment works - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
E coli (faecal coliforms Confirmed)	C002	0 number/100 ml	1,146	0	0	0	0
Total Coliforms (Confirmed)	C001	0 number/100 ml	1,146	0	0	0	0
Totals:			2,292	0			

Table DVW 3: Quality of water leaving treatment works - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Colony Counts)	C007	No abnormal change	1,146	-n/a	0	5
Colony Counts After 48 Hours At 37°C (Colony Counts)	C013	No abnormal change	1,146	-n/a	0	2
Residual Disinfectant - Free	C009	No abnormal change	1,147	-n/a	0.13	0.76
Residual Disinfectant - Total	C010	No abnormal change	1,147	-n/a	0.17	0.85
<i>Combined Chlorine/Residual Disinfectant Combined*</i>	-(n/a)	-(n/a)	(1,147)	-n/a	0	0.16
Turbidity - Indicator	A002A	1 nephelometric turbidity units	1,145	0	< 0.06	0.3554
Totals:			5,731	0		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

Table DVW 4: Quality of water leaving service reservoirs - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
E coli (faecal coliforms Confirmed)	C002	0 number/100 ml	1,430	0	0	0	0
Total Coliforms (Confirmed)	C001	0 number/100 ml	1,430	0	0	0	0
Totals:			2,860	0			

Table DVW 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Colony Counts)	C007	No abnormal change	1,430	-n/a	0	28
Colony Counts After 48 Hours At 37°C (Colony Counts)	C013	No abnormal change	1,430	-n/a	0	2
Residual Disinfectant - Free	C009	No abnormal change	1,430	-n/a	0.03	0.6
Residual Disinfectant - Total	C010	No abnormal change	1,430	-n/a	0.04	0.65
Combined Chlorine/Residual Disinfectant Combined*	-(n/a)	-(n/a)	(1,430)	-n/a	0	0.16
Totals:			5,720	0		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.

Table DVW 6: Quality of water leaving bulk supply points - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
1 2-Dichloroethane (Total)	F001	3 µg/l	51	0	< 0.09	< 0.14	0
Benzene (Total)	F002	1 µg/l	51	0	< 0.04	< 0.05	0
Boron	D005A	1 mg B/l	51	0	0	0.022	0
Bromate	F003	10 µg BrO3/l	51	0	< 0.1	< 0.25	0
Cyanide (Total)	B003	50 µg CN/l	51	0	< 0.7	2.4	0
Fluoride (Total)	A027	1.5 mg F/l	51	0	< 0.004	0.13	0
Mercury (Total)	B005	1 µg Hg/l	51	0	< 0.015	< 0.022	0
Pesticides (Total by Calculation)	B010	0.5 µg/l	51	0	0	0.029	0
Pesticides 2 4-D	P020	0.1 µg/l	52	0	< 0.003	< 0.01	0
Pesticides 2 4-DB	P082	0.1 µg/l	52	0	< 0.004	< 0.01	0
Pesticides Aldrin	P002	0.03 µg/l	52	0	0	< 0.003	0
Pesticides Asulam	P133	0.1 µg/l	51	0	< 0.008	< 0.01	0
Pesticides Bromoxynil	P008	0.1 µg/l	52	0	< 0.002	< 0.011	0
Pesticides Clopyralid	P018	0.1 µg/l	51	0	< 0.003	< 0.015	0
Pesticides Dieldrin	P028	0.03 µg/l	52	0	0	< 0.003	0
Pesticides Fluroxypyr	P040	0.1 µg/l	52	0	< 0.002	< 0.01	0
Pesticides Glyphosate	P042	0.1 µg/l	49	0	< 0.009	< 0.011	0
Pesticides Heptachlor	P043	0.03 µg/l	52	0	< 0.001	< 0.01	0
Pesticides Heptachlor Epoxide - Total (Trans, CIS) (Heptachlor Epoxide)	P044	0.03 µg/l	52	0	0	< 0.01	0
Pesticides MCPA 4-chloro-o-tolyloxyacetic acid	P054	0.1 µg/l	53	0	< 0.002	0.01	0
Pesticides MCPP (Mecoprop)	P053	0.1 µg/l	52	0	< 0.002	< 0.01	0
Pesticides Metaldehyde	P226	0.1 µg/l	52	0	< 0.001	< 0.01	0
Pesticides Triclopyr	P131	0.1 µg/l	52	0	< 0.003	< 0.01	0
Radon	F031	100 Bq/l	8	0	7	31.5	0
Trichloroethene & Tetrachloroethene - Sum Of 2 Substances (Total by Calculation)	D009B	10 µg/l	51	0	0	0	0
Totals:			1,243	0			

Table DVW 7: Quality of water leaving bulk supply points - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Tetrachloromethane (Total)	D008	3 µg/l	51	0	< 0.02	< 0.06	0
Totals:			51	0			

Table DVW 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Chloride	D002A	250 mg Cl/l	51	0	7.9	67.9
Clostridium Perfringens	C004A	0 number/100 ml	281	0	0	0
Conductivity (Electrical Conductivity)	D001	2500 µS/cm	293	0	96.76	658.12
Gross Alpha	F004	0.1 Bq/l	24	0	< 0.014	0.086
Gross Beta	F005	1 Bq/l	28	0	< 0.012	0.11
Sulphate	A007	250 mg SO ₄ /l	51	0	11.83	100
Total Organic Carbon	A017	No abnormal change	51	-n/a	< 0.3	3.1
Totals:			779	0		

Table DVW 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Antimony	B008A	5 µg Sb/l	112	0	< 0.037	0.22436	0
Arsenic (Total)	B001A	10 µg As/l	112	0	0.06682	7.448	0
Benzo[a]Pyrene (Total)	D007	0.01 µg/l	114	0	0	< 0.001	0
Bromate	F003	10 µg BrO ₃ /l	56	0	< 0.1	< 0.25	0
Cadmium (Total)	B002	5 µg Cd/l	112	0	< 0.006	0.15	0
Chromium (Total)	B004	50 µg Cr/l	112	0	< 0.1	2.927	0
Copper (Total)	A024A	2 mg Cu/l	112	0	0	0.093484	0
E coli (faecal coliforms Confirmed)	C002	0 number/100 ml	730	0	0	0	0
Enterococci (Confirmed)	C003	0 number/100 ml	112	0	0	0	0
Lead (10 - will apply 25.12.2013)	B007B	10 µg Pb/l	112	0	< 0.1	3.779	0
Nickel (Total)	B006A	20 µg Ni/l	112	0	0.3	2.944	0
Nitrate (Total)	A012	50 mg NO ₃ /l	112	0	< 0.8726	17.8932	0
Nitrite - Consumer's Taps	A013A	0.5 mg NO ₂ /l	112	0	0	< 0.007	0
Nitrite/Nitrate formula	A013C	1 mg NO ₂ /l	112	0	< 0.02	0.3609	0
Polycyclic Aromatic Hydrocarbons (Total by Calculation)	B011F	0.1 µg/l	113	0	0	0.004	0
Selenium (Total)	B009	10 µg Se/l	112	0	< 0.04	1.644	0
Trihalomethanes (Total by Calculation)	D011	100 µg/l	114	0	0	51.012	0
Totals:			2,471	0			

Table DVW 10: Quality of water at consumer's tap (zones) - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Aluminium (Total)	A021	200 µg Al/l	338	0	< 2.5	38.64	0
Colour	A001	20 mg/l Pt/Co scale	339	0	< 0.19	2.6	0
Iron (Total)	A022	200 µg Fe/l	339	0	< 3	123.4	0
Manganese (Total)	A023	50 µg Mn/l	338	0	0.078	6.61	0
Odour	A003	0 Dilution number	340	2	0	0	2
Sodium (Total)	A009	200 mg Na/l	112	0	5.328	35.974	0
Taste (Taste Quant)	A004	0 Dilution number	339	2	0	0	2
Turbidity	A002	4 nephelometric turbidity units	341	0	< 0.06	0.3932	0
Totals:			2,486	4			

Table DVW 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Total)	A014	0.5 mg NH4/l	339	0	< 0.006	< 0.018
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	730	4	0	0
Colony Counts After 3 Days At 22°C (Colony Counts)	C007	No abnormal change	341	-n/a	0	160
Colony Counts After 48 Hours At 37°C (Colony Counts)	C013	No abnormal change	341	-n/a	0	125
Hydrogen ion (pH) - Indicator (Hydrogen ion) (pH)	A006	6.5 - 9.5 pH Value	340	0	7.0382	8.1259
Residual Disinfectant - Free	C009	No abnormal change	731	-n/a	0.03	0.6236
Residual Disinfectant - Total	C010	No abnormal change	731	-n/a	0.08	0.7368
<i>Combined Chlorine/Residual Disinfectant Combined*</i>	<i>-(n/a)</i>	<i>-(n/a)</i>	<i>(731)</i>	<i>-n/a</i>	<i>0.02</i>	<i>0.23</i>
Totals:			3,553	4		

*Residual disinfectant combined is presented for information. It is not a parameter required by the regulations. It is derived from the parameters 'Residual Disinfectant - Total' minus 'Residual Disinfectant - Free'.