

Data summary tables for SES Water (SES)

These tables contain a summary of results of monitoring undertaken by the water company in 2017 and submitted to the Drinking Water Inspectorate. The tables are published by the Inspectorate as part of the Chief Inspector's Report entitled *Drinking water 2017*.

The tables and full content of the Drinking Water Inspectorate's annual report are available on the Inspectorate's website at <http://www.dwi.defra.gov.uk>

Notes relating to the interpretation of the tables:

Columns on the following tables that are headed '1 percentile representing a minimum' and '99 percentile representing a maximum' contain figures for the 1 percentile and 99 percentile sample results respectively except where less than 100 samples were taken, when the figures are the actual maximum and minimum results.

The symbol < indicates that the result was less than the limit of detection of the analytical method used.

Published 11 July 2018
Drinking Water
Inspectorate Area 1A
Nobel House
17 Smith Square
London
SW1P 3JR

Enquiries: 0300 068 6400

Site Summary Data for SES Water

Report Date Range: For the whole year 2017

Table SES 1: Quality of water leaving treatment works - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
Nitrite (Total)	A013B	0.1 mg NO ₂ /l	661	0	< 0.003	0.00638	0
Totals:			661	0			

Table SES 2: Quality of water leaving treatment works - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of works with failures
E coli (faecal coliforms Confirmed)	C002	0 number/100 ml	2,107	0	0	0	0
Total Coliforms (Confirmed)	C001	0 number/100 ml	2,107	0	0	0	0
Totals:			4,214	0			

Table SES 3: Quality of water leaving treatment works - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22°C (Colony Counts)	C007	No abnormal change	2,107	-n/a	0	2
Residual Disinfectant - Total	C010	No abnormal change	2,114	-n/a	0.21	1.09
Turbidity - Indicator	A002A	1 nephelometric turbidity units	2,107	1	< 0.04	0.2192
Totals:			6,328	1		

Table SES 4: Quality of water leaving service reservoirs - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of reservoirs failing standard
E coli (faecal coliforms Confirmed)	C002	0 number/100 ml	1,787	0	0	0	0
Total Coliforms (Confirmed)	C001	0 number/100 ml	1,787	0	0	0	0
Totals:			3,574	0			

Table SES 5: Quality of water leaving service reservoirs - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Colony Counts After 3 Days At 22øc (Colony Counts)	C007	No abnormal change	1,787	-n/a	0	1624
Residual Disinfectant - Total	C010	No abnormal change	1,787	-n/a	< 0.04	0.86
Totals:			3,574	0		

Table SES 6: Quality of water leaving bulk supply points - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Bromate	F003	10 µg BrO3/l	55	0	< 0.4	< 0.4	0
Cyanide (Total)	B003	50 µg CN/l	55	0	< 2	< 2	0
Fluoride (Total)	A027	1.5 mg F/l	55	0	< 0.06	0.21	0
Mercury (Total)	B005	1 µg Hg/l	55	0	< 0.02	< 0.02	0
Pesticides (Total by Calculation)	B010	0.5 µg/l	55	0	0	0.055	0
Pesticides 2 4-D	P020	0.1 µg/l	8	0	< 0.003	0.004	0
Pesticides Aldrin	P002	0.03 µg/l	55	0	< 0.007	0.008	0
Pesticides Atrazine	P004	0.1 µg/l	55	0	< 0.002	0.033	0
Pesticides Azoxystrobin	P227	0.1 µg/l	55	0	< 0.007	< 0.007	0
Pesticides Boscalid	P231	0.1 µg/l	55	0	< 0.005	< 0.005	0
Pesticides Bromoxynil	P008	0.1 µg/l	8	0	< 0.003	< 0.003	0
Pesticides Carbenazim (Total)	P150	0.1 µg/l	55	0	< 0.002	< 0.002	0
Pesticides Carbetamide	P010	0.1 µg/l	55	0	< 0.002	< 0.002	0
Pesticides Chlortoluron	P014	0.1 µg/l	55	0	< 0.002	0.005	0
Pesticides Clopyralid	P018	0.1 µg/l	8	0	0.009	0.017	0
Pesticides Dieldrin	P028	0.03 µg/l	55	0	< 0.006	< 0.006	0
Pesticides Diflufenican	P157	0.1 µg/l	55	0	< 0.003	< 0.003	0
Pesticides Dimethenamid	P245	0.1 µg/l	55	0	< 0.003	< 0.003	0
Pesticides Diuron	P032	0.1 µg/l	55	0	< 0.003	0.007	0
Pesticides Epoxyconazole	P217	0.1 µg/l	55	0	< 0.004	< 0.004	0
Pesticides Flufenacet	P230	0.1 µg/l	55	0	< 0.003	< 0.003	0
Pesticides Fluroxypyr	P040	0.1 µg/l	8	0	< 0.004	< 0.004	0
Pesticides Flutriafol	P039	0.1 µg/l	55	0	< 0.002	< 0.002	0
Pesticides Heptachlor	P043	0.03 µg/l	55	0	< 0.007	< 0.007	0
Pesticides Heptachlor Epoxide - Total (Trans, CIS) (Heptachlor Epoxide)	P044	0.03 µg/l	55	0	< 0.012	< 0.012	0
Pesticides Isoproturon	P048	0.1 µg/l	55	0	< 0.003	< 0.003	0
Pesticides MCPA 4-chloro-o-tolyloxyacetic acid	P054	0.1 µg/l	8	0	< 0.005	< 0.005	0
Pesticides MCPP (Mecoprop)	P053	0.1 µg/l	8	0	< 0.002	0.002	0
Pesticides Metaldehyde	P226	0.1 µg/l	23	0	0.004	0.03	0
Pesticides Metazachlor	P203	0.1 µg/l	55	0	< 0.001	0.001	0
Pesticides Methabenzthiazuron	P167	0.1 µg/l	55	0	< 0.001	< 0.001	0
Pesticides Pendimethalin	P118	0.1 µg/l	55	0	< 0.007	< 0.007	0
Pesticides Picloram (Total)	P122	0.1 µg/l	47	0	< 0.007	0.009	0
Pesticides Propyzamide	P071	0.1 µg/l	55	0	< 0.001	0.004	0
Pesticides Prosulfocarb	P243	0.1 µg/l	55	0	< 0.001	< 0.001	0

Table SES 6: Quality of water leaving bulk supply points - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of supply points with failures
Pesticides Quinmerac	P244	0.1 µg/l	8	0	< 0.005	< 0.005	0
Pesticides Simazine	P073	0.1 µg/l	55	0	< 0.004	0.009	0
Pesticides Tebuconazole	P177	0.1 µg/l	55	0	< 0.002	< 0.002	0
Pesticides Tri-allate	P079	0.1 µg/l	55	0	< 0.005	< 0.005	0
Pesticides Triclopyr	P131	0.1 µg/l	8	0	< 0.005	< 0.005	0
Totals:			1,784	0			

Table SES 8: Quality of water leaving bulk supply points - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Chloride	D002A	250 mg Cl/l	55	0	21.6	52.2
Clostridium Perfringens	C004A	0 number/100 ml	170	0	0	0
Conductivity (Electrical Conductivity)	D001	2500 µS/cm	393	0	330.98	595
Gross Alpha	F004	0.1 Bq/l	8	1	< 0.02	0.17
Gross Beta	F005	1 Bq/l	8	0	< 0.28	< 0.28
Sulphate	A007	250 mg SO4/l	55	0	14.1	79.9
Total Organic Carbon	A017	No abnormal change	55	-n/a	0.31	3.86
Totals:			744	1		

Table SES 9: Quality of water at consumer's tap (zones) - European Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
1 2-Dichloroethane (Total)	F001	3 µg/l	160	0	< 0.04	< 0.04	0
Antimony	B008A	5 µg Sb/l	160	0	< 0.02	0.4563	0
Arsenic (Total)	B001A	10 µg As/l	160	0	< 0.04	1.0473	0
Benzene (Total)	F002	1 µg/l	160	0	< 0.01	0.02	0
Benzo[a]Pyrene (Total)	D007	0.01 µg/l	160	1	< 0.001	0.01385	1
Boron	D005A	1 mg B/l	160	0	0.02261	0.07068	0
Cadmium (Total)	B002	5 µg Cd/l	160	0	< 0.01	0.0395	0
Chromium (Total)	B004	50 µg Cr/l	160	0	< 0.1	2.178	0
Copper (Total)	A024A	2 mg Cu/l	160	0	< 0.001	0.2356	0
E coli (faecal coliforms Confirmed)	C002	0 number/100 ml	1,789	0	0	0	0
Enterococci (Confirmed)	C003	0 number/100 ml	160	0	0	0	0
Lead (10 - will apply 25.12.2013)	B007B	10 µg Pb/l	160	0	< 0.2	6.573	0
Nickel (Total)	B006A	20 µg Ni/l	160	0	< 0.3	4.775	0
Nitrate (Total)	A012	50 mg NO3/l	656	0	5.957	36.8	0
Nitrite - Consumer's Taps	A013A	0.5 mg NO2/l	656	0	< 0.003	0.27458	0
Nitrite/Nitrate formula	A013C	1 mg NO2/l	656	0	0.1	0.743	0
Polycyclic Aromatic Hydrocarbons (Total by Calculation)	B011F	0.1 µg/l	160	0	0	0.0447	0
Selenium (Total)	B009	10 µg Se/l	160	0	< 0.35	1.4507	0
Trichloroethene & Tetrachloroethene - Sum Of 2 Substances (Total by Calculation)	D009B	10 µg/l	160	0	0	5.356	0
Trihalomethanes (Total by Calculation)	D011	100 µg/l	160	0	1	52.6206	0
Totals:			6,317	1			

Table SES 10: Quality of water at consumer's tap (zones) - National Standards

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests Failed	1 percentile (representing a minimum)	99 percentile (representing a maximum)	No. of zones failing standard
Aluminium (Total)	A021	200 µg Al/l	276	0	< 4	43.38	0
Colour	A001	20 mg/l Pt/Co scale	328	0	< 0.8	2.2	0
Iron (Total)	A022	200 µg Fe/l	352	0	< 1	59.17	0
Manganese (Total)	A023	50 µg Mn/l	228	0	< 1.2	4.255	0
Odour	A003	0 Dilution number	328	0	0	0	0
Sodium (Total)	A009	200 mg Na/l	160	0	11.822	29.229	0
Taste (Taste Quant)	A004	0 Dilution number	328	0	0	0	0
Tetrachloromethane (Total)	D008	3 µg/l	160	0	< 0.04	< 0.06	0
Turbidity	A002	4 nephelometric turbidity units	328	0	0.04	0.44	0
Totals:			2,488	0			

Table SES 11: Quality of water at consumer's tap (zones) - Additional Monitoring Requirements

Parameter Name	Parameter Code	Prescribed Concentration or Value	Total Number of Tests	Tests exceeding specification	1 percentile (representing a minimum)	99 percentile (representing a maximum)
Ammonium (Total)	A014	0.5 mg NH ₄ /l	414	0	< 0.02	0.2185
Coliform Bacteria (Indicator)	C001A	0 number/100 ml	1,789	1	0	0
Colony Counts After 3 Days At 22øc (Colony Counts)	C007	No abnormal change	656	-n/a	0	415
Hydrogen ion (pH) - Indicator (Hydrogen ion) (pH)	A006	6.5 - 9.5 pH Value	328	0	7.229	8
Residual Disinfectant - Total	C010	No abnormal change	1,788	-n/a	< 0.04	0.81
Totals:			4,975	1		